

# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Nursing Home Name	Survey Date	Date of Correction
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/10/2008	08/10/2008
RAMSEY VILLAGE	07/18/2008	09/02/2008
RAMSEY VILLAGE	07/18/2008	09/02/2008



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Deficiency Type	Deficiency Category
Fire Safety	Building Construction Deficiencies
Fire Safety	Corridor Walls and Doors Deficiencies
Fire Safety	Fire Alarm Systems Deficiencies
Fire Safety	Automatic Sprinkler Systems Deficiencies
Fire Safety	Automatic Sprinkler Systems Deficiencies
Fire Safety	Building Service Equipment Deficiencies
Fire Safety	Electrical Deficiencies
Health	Resident Rights Deficiencies
Health	Mistreatment Deficiencies



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Deficiency	Scope	Level of Harm
approved construction type or materials.	Widespread	Minimal harm or potential for actual harm
corridor and hallway doors that block smoke.	Pattern	Minimal harm or potential for actual harm
an approved installation, maintenance and testing program for fire alarm systems.	Widespread	Minimal harm or potential for actual harm
an approved automatic sprinkler system connected to the fire alarm system.	Widespread	Minimal harm or potential for actual harm
automatic sprinkler systems that have been maintained in working order.	Pattern	Minimal harm or potential for actual harm
properly protected cooking facilities.	Isolated	Minimal harm or potential for actual harm
properly installed electrical wiring and equipment.	Widespread	Minimal harm or potential for actual harm
Properly hold, secure and manage each resident's personal money which is deposited with the nursing home.	Isolated	Minimal harm or potential for actual harm
Keep each resident free from physical restraints, unless	Isolated	Minimal harm or potential for actual harm



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------

RAMSEY VILLAGE	07/18/2008	09/02/2008
----------------	------------	------------



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Health

Mistreatment Deficiencies

Health

Resident Rights Deficiencies

Health

Resident Assessment Deficiencies

Health

Quality Care Deficiencies

Health

Quality Care Deficiencies

Health

Quality Care Deficiencies

Health

Environmental Deficiencies



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

needed for medical treatment.

Write and use policies that forbid mistreatment, neglect and abuse of residents and theft of residents' property.

Pattern

Minimal harm or potential for actual harm

Provide care in a way that keeps or builds each resident's dignity and self respect.

Isolated

Minimal harm or potential for actual harm

Develop a complete care plan that meets all of a resident's needs, with timetables and actions that can be measured.

Pattern

Minimal harm or potential for actual harm

Give each resident care and services to get or keep the highest quality of life possible.

Pattern

Minimal harm or potential for actual harm

Give residents proper treatment to prevent new bed (pressure) sores or heal existing bed sores.

Pattern

Minimal harm or potential for actual harm

Make sure that residents with reduced range of motion get proper treatment and services to increase range of motion.

Pattern

Minimal harm or potential for actual harm

Make sure that the nursing home area is free of dangers that cause accidents.

Isolated

Actual harm



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

RAMSEY VILLAGE	07/18/2008	09/02/2008
RAMSEY VILLAGE	07/18/2008	09/02/2008
RAMSEY VILLAGE	07/23/2009	07/23/2009
RAMSEY VILLAGE	07/23/2009	07/23/2009
RAMSEY VILLAGE	07/23/2009	07/23/2009
RAMSEY VILLAGE	07/23/2009	08/23/2009
RAMSEY VILLAGE	07/23/2009	08/11/2009
RAMSEY VILLAGE	07/23/2009	08/11/2009
RAMSEY VILLAGE	07/23/2009	08/25/2009
RAMSEY VILLAGE	07/23/2009	07/23/2009



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Health	Pharmacy Service Deficiencies
Health	Administration Deficiencies
Fire Safety	Building Construction Deficiencies
Fire Safety	Corridor Walls and Doors Deficiencies
Fire Safety	Smoke Compartmentation and Control Deficiencies
Fire Safety	Emergency Plans and Fire Drills Deficiencies
Fire Safety	Fire Alarm Systems Deficiencies
Fire Safety	Automatic Sprinkler Systems Deficiencies
Fire Safety	Building Service Equipment Deficiencies
Fire Safety	Electrical Deficiencies



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Properly mark drugs and other similar products.	Pattern	Minimal harm or potential for actual harm
Follow all laws and professional standards.	Pattern	Minimal harm or potential for actual harm
approved construction type or materials.	Isolated	Minimal harm or potential for actual harm
corridor and hallway doors that block smoke.	Isolated	Minimal harm or potential for actual harm
smoke barrier doors that can resist smoke for at least 20 minutes.	Isolated	Minimal harm or potential for actual harm
record of quarterly fire drills for each shift under varying conditions.	Widespread	Minimal harm or potential for actual harm
a fire alarm system that can be heard throughout the facility.	Widespread	Minimal harm or potential for actual harm
an approved automatic sprinkler system connected to the fire alarm system.	Widespread	Minimal harm or potential for actual harm
heating and ventilation systems that have been properly installed according to the manufacturer's instructions.	Isolated	Minimal harm or potential for actual harm
properly installed electrical wiring and equipment.	Isolated	Minimal harm or potential for actual harm



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	07/28/2009	08/21/2009
RAMSEY VILLAGE	09/10/2010	10/10/2010



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Health

Resident Rights Deficiencies

Health

Resident Assessment Deficiencies

Health

Quality Care Deficiencies

Health

Environmental Deficiencies

Health

Nutrition and Dietary Deficiencies

Health

Nutrition and Dietary Deficiencies

Health

Environmental Deficiencies

Health

Environmental Deficiencies

Health

Resident Rights Deficiencies



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Provide care in a way that keeps or builds each resident's dignity and self respect.	Isolated	Minimal harm or potential for actual harm
Develop a complete care plan that meets all of a resident's needs, with timetables and actions that can be measured.	Pattern	Minimal harm or potential for actual harm
Make sure that residents who cannot care for themselves receive help with eating/drinking, grooming and hygiene.	Isolated	Minimal harm or potential for actual harm
Make sure that the nursing home area is free of dangers that cause accidents.	Isolated	Minimal harm or potential for actual harm
Make sure that residents are well nourished.	Pattern	Minimal harm or potential for actual harm
Store, cook, and give out food in a safe and clean way.	Pattern	Minimal harm or potential for actual harm
Have a program to keep infection from spreading.	Isolated	Minimal harm or potential for actual harm
Make sure that a working call system is available in each resident's room or bathroom and bathing area.	Isolated	Minimal harm or potential for actual harm
Let each resident choose a personal doctor.	Widespread	Potential for minimal harm



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

RAMSEY VILLAGE	09/10/2010	10/10/2010
----------------	------------	------------

RAMSEY VILLAGE	09/10/2010	10/10/2010
----------------	------------	------------

RAMSEY VILLAGE	09/10/2010	10/10/2010
----------------	------------	------------

RAMSEY VILLAGE	09/13/2010	10/13/2010
----------------	------------	------------

RAMSEY VILLAGE	09/13/2010	10/13/2010
----------------	------------	------------

RAMSEY VILLAGE	09/13/2010	10/13/2010
----------------	------------	------------

RAMSEY VILLAGE	09/13/2010	10/13/2010
----------------	------------	------------



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

Health

Resident Rights Deficiencies

Health

Quality Care Deficiencies

Health

Quality Care Deficiencies

Fire Safety

Building Construction Deficiencies

Fire Safety

Corridor Walls and Doors Deficiencies

Fire Safety

Building Service Equipment Deficiencies

Fire Safety

Electrical Deficiencies



# Ramsey Village - 3 Year Annual I

Based on Nursing Home Compare - Survey Deficiency

personal doctor.

Provide care in a way that keeps or builds each resident's dignity and self respect.	Isolated	Minimal harm or potential for actual harm
--	----------	---

Give professional services that meet a professional standard of quality.	Isolated	Minimal harm or potential for actual harm
--	----------	---

Make sure that each resident who enters the nursing home without a catheter is not given a catheter, unless it is necessary.	Isolated	Minimal harm or potential for actual harm
--	----------	---

approved construction type or materials.	Isolated	Minimal harm or potential for actual harm
--	----------	---

corridor and hallway doors that block smoke.	Isolated	Minimal harm or potential for actual harm
--	----------	---

heating and ventilation systems that have been properly installed according to the manufacturer's instructions.	Pattern	Minimal harm or potential for actual harm
---	---------	---

properly installed electrical wiring and equipment.	Isolated	Minimal harm or potential for actual harm
---	----------	---